



Proposed Code Change  
State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 5/12/09

Code 19-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title IRC		Edition
Section number and title R302.5.1 Opening protection		Page 51
Proponent Jeff Washler	Title	
Address 3435 CR 52, Auburn IN 46706		Phone 260.925.8427
PROPOSED CODE CHANGE (Check One)		
X Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>Change second sentence to read as: "Other openings between the garage and residence shall be equipped with an exterior grade door capable of sealing the opening.</p>		
REASON AND FISCAL IMPACT		
<p>Many home owners are changing out steel doors for fiberglass doors after the final inspection so that their doors match.</p> <p>Should have no fiscal impact because it does not require more than previously required</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		